

Table 7.2: Details of Drinking Water Supply, (2021)

Name of Urban Town/Year	Name of Water Source	Capacity (million litres per day)	Hours of water supply per day	Water treatment facility	Expenditure incurred for the services annually (million Nu.)	Year of Construction	Coverage (Area/places)	Remarks
Zhemgang	Dechengang	116 litres/capital /per day	9 hours in summer and 6 hours in lean season	Slow sand filtration with clorination faccility	0.5 million	2003	1.1 sqkm	construction of new water source is going on
Tingtibi	Takarbe	195 litres/capital /perday	24 hours	Slow sand filtration with clorination facility			0.5 sqkm	Using old source

Year 2022

Zhemgang town	Dechengang	116 litres/capital /per day	9 hrs in summer and 6 hrs in winter	Slow sand Filtration with clorination facility	0.5	2003	1.1 Sqkm	Additional temporary line is connected in the treatment plant from sershong source
---------------	------------	-----------------------------	-------------------------------------	--	-----	------	----------	--

Source: Dzongkhag Municipal/Thromde